

Date: 11 July 2014

Report No: 140302r

Page: 1 of 7

GridX Power Pty Ltd
GPO Box 4372
Sydney NSW 2001

Emission Testing – June 2014
DP1 and DP2

Dear Mr Chris Smith,

Tests were performed 24 June 2014 to determine emissions to air from 2 locations at the Botany plant of GridX Power Pty Ltd.

EXECUTIVE SUMMARY	2
RESULTS	3
DP 1 – Unit 1	3
DP 2 – Unit 2	4
SAMPLING PLANE OBSERVATIONS	5
PLANT OPERATING CONDITIONS	5
TEST METHODS	6
DEFINITIONS	7

Yours faithfully
Emission Testing Consultants



Aaron Davis BSc, LLB (Hons)
State Manager

ad@emission.com.au

EXECUTIVE SUMMARY

Emission Testing Consultants (ETC) was engaged by GridX Power Pty Ltd to perform emission monitoring to satisfy conditions within NSW Environment Protection Licence 20246 in respect of the trigeneration facility located at Botany NSW. Monitoring was performed on Discharge Points 1 and 2 (DP1 and DP2) and for the following parameters:

- Nitrogen oxides (NO_x);
- Volatile Organic Compounds (VOCs);
- Oxygen;

Testing was conducted on DP1 and DP2 on 24 June 2014 under maximum load conditions. Testing on both DP1 and DP2 was conducted with the Chilling Unit on.

The methodologies chosen by ETC are those recommended by NSW EPA publication *The Approved Methods for Sampling and Analysis of Air Pollutants in NSW* January 2007.

RESULTS

DP 1 – Unit 1

24 June 2014



Flow Results		Measured MW	DP1 - Engine 1 140302
Date and time of flow test		24/06/2014 9:37	
Date and time of flow test		24/06/2014 10:43	
Stack dimensions at sampling plane		900	mm
Velocity at sampling plane		20	m/s
Average temperature		286	°C
Moisture content	Alt008	8.7	% v/v
Flow rate at discharge conditions		12	m ³ /sec
Flow rate at wet NTP conditions		6.0	m ³ /sec
Flow rate at dry NTP conditions		5.5	m ³ /sec

Continuous Analyser Results	DP1 - Engine 1 140302 330	Sampling Times	Concentration at NTP	Concentration at 3% O ₂	Mass rate
Oxygen (dry basis)		0941-1040	10.2 % v/v	-	-
Dry gas density		0941-1040	1.3 kg/m ³	-	-
Molecular weight of stack gas, dry basis		0941-1040	29 g/g-mole	-	-
Nitrogen oxides as NO ₂		0941-1040	73 mg/m ³	120 mg/m ³	24 g/min

Volatile Organic Compound (VOC) Results	DP1 - Engine 1 140302 330	Sampling Times	Concentration at NTP	Concentration at 3% O ₂	Mass rate
Total VOC as n-propane		0941-1040	< 0.6 mg/m ³	< 1 mg/m ³	< 0.2 g/min

Refer to "SAMPLING PLANE OBSERVATIONS" on page 5.

DP 2 – Unit 2
24 June 2014



Flow Results		Measured MW	DP2 - Engine 2 140302
Date and time of flow test		24/06/2014 11:15	
Date and time of flow test		24/06/2014 12:21	
Stack dimensions at sampling plane		900	mm
Velocity at sampling plane		19	m/s
Average temperature		283	°C
Moisture content	Alt008	9.8	% v/v
Flow rate at discharge conditions		12	m ³ /sec
Flow rate at wet NTP conditions		6.0	m ³ /sec
Flow rate at dry NTP conditions		5.4	m ³ /sec

Continuous Analyser Results	DP2 - Engine 2 140302 330	Sampling Times	Concentration at NTP	Concentration at 3% O2	Mass rate
Oxygen (dry basis)		1119-1218	10.4 % v/v	-	-
Dry gas density		1119-1218	1.3 kg/m ³	-	-
Molecular weight of stack gas, dry basis		1119-1218	29 g/g-mole	-	-
Nitrogen oxides as NO ₂		1119-1218	67 mg/m ³	110 mg/m ³	22 g/min

Volatile Organic Compound (VOC) Results	DP2 - Engine 2 140302 330	Sampling Times	Concentration at NTP	Concentration at 3% O2	Mass rate
Total VOC as n-propane		1119-1218	< 0.6 mg/m ³	< 1 mg/m ³	< 0.2 g/min

Refer to “**SAMPLING PLANE OBSERVATIONS**” on page 5.

SAMPLING PLANE OBSERVATIONS

DP1

The sampling plane had 2 x 1 inch BSP Ports. The location was determined to be “non-ideal” as per AS4323.1. It was 4 duct diameters less than the required 6 duct diameters downstream from a junction. It was more than the required 2 duct diameters upstream from the exit. The number of sampling points was increased as per AS4323.1. The sampling plane passed the flow assessment (items (a) to (f) of AS4323.1) and was therefore “compliant”.

DP2

The sampling plane had 2 x 1 inch BSP Ports. The location was determined to be “non-ideal” as per AS4323.1. It was 4 duct diameters less than the required 6 duct diameters downstream from a junction. It was more than the required 2 duct diameters upstream from the exit. The number of sampling points was increased as per AS4323.1. The sampling plane passed the flow assessment (items (a) to (f) of AS4323.1) and was therefore “compliant”.

PLANT OPERATING CONDITIONS

Plant operating conditions were supplied by GridX personnel.

Testing was conducted on DP1 and DP2 on 24 June 2014 under maximum load conditions. Testing on both DP1 and DP2 was conducted with the Chilling Unit turned on.

TEST METHODS

The following methods are accredited with the National Association of Testing Authorities (NATA) and are approved for the sampling and analysis of gases unless otherwise stated. Specific details of the methods are available on request.

All sampling and analysis was conducted in accordance with the test methods (TM) prescribed in NSW EPA's *Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales*, Jan 2007 and in accordance with the *Protection of the Environment Operations (Clean Air) Regulation 2010* unless otherwise specified.

All parameters are reported adjusted to dry NTP conditions unless otherwise stated.

Parameter	Sampling			Analysis			
	NATA	NSW TM Method	Sampling Method	NATA	Analytical Laboratory	Analytical Method	Analytical Laboratory Report Number(s)
Selection of sampling positions	Yes	TM-1	AS4323.1	Yes	Emission Testing Consultants	NA	140302r
Flow rate	Yes	TM-2	USEPA 2	Yes		NA	
Velocity	Yes	TM-2	USEPA 2	Yes		NA	
Temperature	Yes	TM-2	USEPA 2	Yes		NA	
Moisture	Yes	TM-22	USEPA ALT008	Yes		NA	
Dry gas Density	Yes	TM-23	USEPA 3	Yes		USEPA 3	
Molecular weight	Yes	TM-23	USEPA 3	Yes		USEPA 3	
Oxygen (O ₂)	Yes	TM-25	USEPA 3A	Yes		USEPA 3A	
Nitrogen oxides (NO _x) as NO ₂	Yes	TM-11	USEPA 7E	Yes		USEPA 7E	
Volatile organic compounds (VOC)	Yes	TM-34	USEPA 18	Yes	SGS Australia Pty Ltd	AN467	85786

DEFINITIONS

The following symbols and abbreviations are used in test reports:

BSP	British standard pipe.
Concentration	Mass of analyte per cubic metre expressed at NTP dry conditions (ng, µg or mg/m ³).
Flow rate at discharge conditions	Volume of gas flow per unit time expressed at discharge temperature, pressure and moisture content (m ³ /min).
Flow rate at wet NTP conditions	Volume of gas flow per unit time expressed at 0°C, an absolute pressure of 101.325 kPa and discharge moisture content (m ³ /min).
Flow rate at dry NTP conditions	Volume of gas flow per unit time expressed at 0°C, an absolute pressure of 101.325 kPa and 0% moisture content (m ³ /min).
Mass rate	Mass of analyte per unit time (µg, mg or g/min).
Moisture content	Percentage of gaseous moisture in the gas expressed on a volume / volume percentage basis. This does not include moisture in the gas stream that is in the liquid phase (free moisture).
NA	Not applicable.
NTP	Normal temperature and pressure. Gas volumes and concentrations are expressed on a dry (wet in the case of odour only) basis at 0°C, at discharge oxygen concentration and an absolute pressure of 101.325 kPa, unless otherwise specified.
Sampling plane	Location at which measurements were conducted.
TOC	Total Organic Compounds. Total gaseous organic concentration of vapours consisting primarily of alkanes, alkenes, and/or arenes (aromatic hydrocarbons) The concentration can be expressed in terms of propane, hexane (or other appropriate organic calibration gas) or in terms of methane.
Velocity	Gas velocity expressed at discharge temperature, pressure and moisture content (m/s)
VOC	Any chemical compound based on carbon in the boiling range 36 to 126°C, with a vapour pressure of at least 0.010kPa at 25°C (or having a corresponding volatility under the particular conditions of use) that adsorb onto activated charcoal and desorb into CS ₂ , or that can be collected in a tedlar bag and be quantitatively recovered, and that are detected by GCMS. These compounds may contain oxygen, nitrogen and other elements, but specifically excluded are CO, CO ₂ , carbonic acid, metallic carbides and carbonate salts.
>	Greater than.
<	Less than the minimum limit of detection using the specified method.
~	Approximately.